

ANNEXURE- I

(Annexure to G.O.Ms.No.56, Home (Ser.IV) Department, Dated: 26-07-2019)

Instructions to be followed for schools existing before 13.04.2009;

SELF CERTIFICATION FORM

Self Certification of Fire Safety Measures by School Management;

i) General Information for School Buildings of all categories i.e., A, B, C&D.

S.No	Details	12-07-2002
1	Date of the opening of the school building	
2	Name of the applicant	Mr. Chinnappa Reddy
3	Name and address of the school	Anna Memorial High School
4	Telephone number and email of the applicant	9866410780 fatherchinnappa@gmail.com
5	Height of the building(in meters)	9.753 mtr
6	No of floors	G+2
7	Abutting road width (in meters)	8.534 Mtr
8	Built-up area of each floor in Sq.Mtrs	
	Stilt	Ground - 945.75 Mtr
	Ground	1st Flw - 945.75 Mtr
	Floor 1	2nd Flw - 945.75 Mtr
	Floor 2	
9	Number of Staircases	
	Staircase 1 (width in meters)	1. 1.5 Mtr
	Staircase 2 (width in meters)	2. 1.35 Mtr
		3. 1.00 Mtr
		4. 1.00 Mtr
10	Width of each Staircases	
11	Open Spaces	
	Front (width in meters)	7 Mtr
	Side 1 (width in meters)	2 Mtr
	Side 2 (width in meters)	3 Mtr
	Rear (width in meters)	1 Mtr

Anna Memorial High School was established before 13.04.2009. Documents proving its establishment prior to 13.04.2009 were submitted to the office of District Fire officer. So this School is qualified to Submit Self-Certification forms to the office of the District Fire officer, Yadadri Division and the same were submitted.

15/03/2022



Chinnappa Reddy
10/3/2022


Signature with date of
School authority and Seal

Manager
ANNA MEMORIAL HIGH SCHOOL
CHOUTUPPAL
Dist. Yadadri Bhuvanagiri (T.S.)

B) School Building with Ground plus two floors and less than 15 Meters in Height.

Sl.No	Fire equipment required	Scale of Fire equipment as per Norms	Required	Provided Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius	15	yes
2	First Aid Hose Reel (IS:884:1985)	1 No for every 1000 square meter	3 Hose Reels	yes
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	30,000 Ltrs	yes
4	Automatic Sprinkler System (IS 15105:2002) The is standard may be downloaded from www.http://bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters	NA	NA
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg/cm ²	450 LPM(450 LPM additionally shall be provided if basement exceeds 200 square meters)	2 Nos Booster pumps 450 LPM	yes
Additional Fire Safety Measures in lieu of deficiency in Setbacks				
1	Water Shower Curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.	yes	yes
2	Fire Brigade inlet	02 Nos	yes	yes

Note: If the floor area in a single floor more than 500 square meters and if there is only single case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.



Signature with date of 10/3/2022
School authority and Seal

Manager
ANNA MEMORIAL HIGH SCHOOL
CHOUTUPPAL
Dist. Yadadri Bhuvanagiri (T.S.)

ii) General Fire Safety Measures which should be followed by all schools:-

S.No	General Fire Safety Measures	Whether followed Yes/No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials	yes
2	It should be ensured that the available Fire safety Equipment is always in good working condition	yes
3	Pre-school, kinder Garden and Class/Grade 1 Students shall be located on Ground Floor/level of Exit discharge	yes
4	Kitchen should be constructed/provided away from the school building	-
5	All Schools shall prepare an Evacuation Plan in consultation with local Fire Officer	yes
6	All Teachers /Employees should be trained in operating the available Fire Safety Equipment in the building	yes
7	All Exits/Escapes routes shall be kept free from any obstructions for free passage in case of any emergency.	yes
8	All the internal staircase, lifts, lobbies and corridors should be adequately ventilated and illuminated.	yes
9	If the school is provided with central Air-Conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed	-
10	School Building shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.	-
11	Any Hazardous/Combustible Material/Volatile Flammable Liquids shall not be stored in School Building.	yes
12	Dos and DON'TS in case of any Fire/Emergency shall be properly displayed at Strategic locations of the building	yes
13	Auto Glow Sign Boards shall be provided indicating Exits/Escapes Routes.	yes
14	Electric Wiring in the entire building shall be checked and certified by the competent authority.	yes
15	Structural Stability of the building shall be checked and certified by the competent authority.	yes
16	Public Address System shall be provided for use case of any emergency and this system shall cover the entire building.	yes
17	Detailed information regarding the number of students in each Class Room and the member of teacher/employees working shall be displayed at Strategic locations of the building.	yes
18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals/Ambulance etc. on all floors and at Strategic Locations.	yes

Contd/-2


10/3/2022
Manager
ANNA MEMORIAL HIGH SCHOOL
CHOUTUPPAL
Dist. Yadadri Bhuvanagiri (T.S.)

S.No	General Fire Safety Measures	Whether followed Yes/No
19	A pictorial map with the details of Entries/exits, Details of Class Rooms/Laboratories/Staff Rooms and open Place (Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	Yes
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler System as per IS 15105:2002	—

We Chinnappa Reddy . G School
Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provide is false ,we understand that our school affiliation may be cancelled by the Concerned Authority .We have installed fire safety measures as per the Annexure I and undertake to maintain the same good working condition at all times.

Chinnappa Reddy . G
10/3/2022

Signature with date of
School authority and Seal
Name& Designation

Manager
ANNA MEMORIAL HIGH SCHOOL
CHOUTUPPAL
Dist. Yadadri Bhuvanagiri (T.S.)